

## TESTTRANSFO2 operation

**This instrument must not be used on a powered-up transformer.  
Power-down the the transformer according to the prescribed procededures.**

### Principle :

- Test of the state of the protections
- Test for most causes of fault by injection of a very low voltage, applying series of 19 measurements including the transformer ratio on all 3 phases.



### Use :

Once the transformer is isolated from the network, connect all the leads to the terminals and the earth. Press the **GREEN** button, TESTTRANSFO2 initialises. Press the **GREEN** button again, TESTTRANSFO2 runs the 19 measurements automatically.



3 ranges of measurements are possible, so as to maintain the measurement precision of the transformation ratios :  
- Ranges: 20KV-33KV (default) / 10KV-19KV / 5KV-9KV  
- The correct choice of range is essential for a good final result.

The first 13 tests check for the presence / absence of continuity. The 6 following tests check the transformation ratios of the three phases

The TESTTRANSFO2 gives the result "OK" or "ERROR".  
A transformer is considered healthy if 19 tests were all successfully passed.



The black button enables :  
- either changing the range.  
- or recording the measurements, so as to transfer them to a PC. (capacity 10 measurements)



The **RED** button is Used to turn-off the instrument.



© Reproduction et communication interdites sans autorisation écrite de MADE.

DECEMBER 2013  
MADE - V 1.00



**MADE S.A.**  
167, Impasse de la garrigue  
F 83210 LA FARLEDE

E-mail : [contact@made-sa.com](mailto:contact@made-sa.com)  
Web : <http://www.made-sa.com>

Tél : + 33 (0) 494 083 198  
FAX : + 33 (0) 494 082 879



## TESTTRANSFO2 operation

**This instrument must not be used on a powered-up transformer.  
Power-down the the transformer according to the prescribed procededures.**

### Principle :

- Test of the state of the protections
- Test for most causes of fault by injection of a very low voltage, applying series of 19 measurements including the transformer ratio on all 3 phases.



### Use :

Once the transformer is isolated from the network, connect all the leads to the terminals and the earth. Press the **GREEN** button, TESTTRANSFO2 initialises. Press the **GREEN** button again, TESTTRANSFO2 runs the 19 measurements automatically.



3 ranges of measurements are possible, so as to maintain the measurement precision of the transformation ratios :  
- Ranges: 20KV-33KV (default) / 10KV-19KV / 5KV-9KV  
- The correct choice of range is essential for a good final result.

The first 13 tests check for the presence / absence of continuity. The 6 following tests check the transformation ratios of the three phases

The TESTTRANSFO2 gives the result "OK" or "ERROR".  
A transformer is considered healthy if 19 tests were all successfully passed.



The black button enables :  
- either changing the range.  
- or recording the measurements, so as to transfer them to a PC. (capacity 10 measurements)



The **RED** button is Used to turn-off the instrument.



© Reproduction et communication interdites sans autorisation écrite de MADE.

DECEMBER 2013  
MADE - V 1.00



**MADE S.A.**  
167, Impasse de la garrigue  
F 83210 LA FARLEDE

E-mail : [contact@made-sa.com](mailto:contact@made-sa.com)  
Web : <http://www.made-sa.com>

Tél : + 33 (0) 494 083 198  
FAX : + 33 (0) 494 082 879



**This instrument must not be used on a powered-up transformer.  
Power-down the the transformer according to the prescribed procededures.**

**Running the tests:**

**Important Reminder: all the MV & LV connections of the transformer must be disconnected during the test.**


The TestTransfo2 automatically runs

- A series of tests for each of the 13 completed circuits listed below,
- A record of the transformation ratio obtained by signal analysis from the results 14 to 19, whilst verifying the conformity with the expected result for each case.

The nature of the faults revealed is shown after the test by scrolling through the results using the green button

Note :

- TestTransfo2 does not check the insulation.
- Always ensure that the crocodile clips are making good contact :
- Scrape away paint or dirt if necessary.



Tests Results					
1	✓	Neutral (sec.) / MVA (prim.) open circuit	10	✓	Earth (frame) / LV.a (sec.) open circuit
2	✓	Neutral (sec.) / MV.B (prim.) open circuit	11	✓	Earth (frame) / LV.b (sec.) open circuit
3	✓	Neutral (sec.) / M.V.C (prim.) open circuit	12	✓	Earth (frame) / LV.c (sec.) open circuit
4	✓	Earth (frame) / MVA (prim.) open circuit	13	✓	Earth (frame) / Neutral (sec.) open circuit
5	✓	Earth (frame) / MV.B (prim.) open circuit	14	✓	MVA (prim.) wave coherency
6	✓	Earth (frame) / M.V.C (prim.) open circuit	15	✓	MVB (prim.) wave coherency
7	✓	Neutral (sec.) / LV.a (sec.) continuity	16	✓	MVC (prim.) wave coherency
8	✓	Neutral (sec.) / LV.b (sec.) continuity	17	✓	LV.a (sec.) wave coherency ratio=47.61
9	✓	Neutral (sec.) / LV.c (sec.) continuity	18	✓	LV.b (sec.) wave coherency ratio=47.41
			19	✓	LV.c (sec.) wave coherency ratio=47.82

**Standard :** CE  
 NF EN 50082-1 : CEM  
 NF EN 61010-1 : Electric safety.  
 Protection class : IP 32 – IK 07

<b>Power supply</b>	9 volts battery , type LR61
<b>Dimensions</b>	440 x 280 x 320 mm
<b>Composition</b>	Plastic case
<b>Weight</b>	0.3 Kg
<b>Display :</b>	LCD screen 4 lines + led

FS\_TESTTRANSFO2\_V\_1\_00\_US

**This instrument must not be used on a powered-up transformer.  
Power-down the the transformer according to the prescribed procededures.**

**Running the tests:**

**Important Reminder: all the MV & LV connections of the transformer must be disconnected during the test.**


The TestTransfo2 automatically runs

- A series of tests for each of the 13 completed circuits listed below,
- A record of the transformation ratio obtained by signal analysis from the results 14 to 19, whilst verifying the conformity with the expected result for each case.

The nature of the faults revealed is shown after the test by scrolling through the results using the green button

Note :

- TestTransfo2 does not check the insulation.
- Always ensure that the crocodile clips are making good contact :
- Scrape away paint or dirt if necessary.



Tests Results					
1	✓	Neutral (sec.) / MVA (prim.) open circuit	10	✓	Earth (frame) / LV.a (sec.) open circuit
2	✓	Neutral (sec.) / MV.B (prim.) open circuit	11	✓	Earth (frame) / LV.b (sec.) open circuit
3	✓	Neutral (sec.) / M.V.C (prim.) open circuit	12	✓	Earth (frame) / LV.c (sec.) open circuit
4	✓	Earth (frame) / MVA (prim.) open circuit	13	✓	Earth (frame) / Neutral (sec.) open circuit
5	✓	Earth (frame) / MV.B (prim.) open circuit	14	✓	MVA (prim.) wave coherency
6	✓	Earth (frame) / M.V.C (prim.) open circuit	15	✓	MVB (prim.) wave coherency
7	✓	Neutral (sec.) / LV.a (sec.) continuity	16	✓	MVC (prim.) wave coherency
8	✓	Neutral (sec.) / LV.b (sec.) continuity	17	✓	LV.a (sec.) wave coherency ratio=47.61
9	✓	Neutral (sec.) / LV.c (sec.) continuity	18	✓	LV.b (sec.) wave coherency ratio=47.41
			19	✓	LV.c (sec.) wave coherency ratio=47.82

**Standard :** CE  
 NF EN 50082-1 : CEM  
 NF EN 61010-1 : Electric safety.  
 Protection class : IP 32 – IK 07

<b>Power supply</b>	9 volts battery , type LR61
<b>Dimensions</b>	440 x 280 x 320 mm
<b>Composition</b>	Plastic case
<b>Weight</b>	0.3 Kg
<b>Display :</b>	LCD screen 4 lines + led

FS\_TESTTRANSFO2\_V\_1\_00\_US